

Date		WTP Water Discharge				Licence Compliance
		pH	TSS	BOD	Aluminium	
Licence Limit		6.5-8.5	100	20	None Stipulated	
	<b>18/07/2018</b>	7.4	1	1	0.22	Yes
	<b>22/08/2018</b>	7.5	4	2	0.22	Yes
	<b>19/09/2018</b>	7.2	29	1	2.76	Yes
	<b>25/10/2018</b>	7.7	1	1	0.17	Yes
	<b>13/11/2019</b>	7.7	5	3	0.43	Yes
	<b>11/12/2018</b>	7.8	3	2	0.26	Yes
	<b>17/01/2019</b>	7.8	1	1	0.31	Yes
	<b>21/02/2019</b>	7.5	14	3	0.15	Yes
	<b>20/03/2019</b>	7.8	12	3	0.45	Yes
	<b>18/04/2019</b>	7.6	1	1	0.12	Yes
	<b>21/05/2019</b>	7.6	32	1	0.2	Yes
	<b>20/06/2019</b>	7.6	1	1	0.16	Yes
	Count	12	12	12	12	
	Min	7.2	1	1	0.12	
	Mean	7.6	8.67	1.67	0.45	
	Max	7.8	32	3	2.76	
	90th percentile	7.8	27.5	3	0.448	
	90th percentile limit	6.5 - 8.5	100	20	N/A	